

STAINLESS STEEL RAINSTOPPER WITH NYLON HANDLE SPECIFICATION

➡ **INTENT:** To reduce inflow, street-level contaminants, sewer odors, traffic-related manhole noise, and cover displacement in municipal sanitary sewer systems.

① **SCOPE:** The contractor shall supply and install a Rainstopper manhole insert per manufacturer recommendations, contract drawings, and these specifications.

② MATERIALS AND DESIGN

2.1 GENERAL

The Rainstopper insert and components shall be manufactured from materials resistant to hydrogen sulfide, dilute sulfuric acid, sewer gases, road oils, and other conditions commonly encountered in municipal wastewater collection systems.

2.2 INSERT

The insert body shall be manufactured from 304 stainless steel with a minimum thickness of 18 gauge.

The manufacturer shall provide load-test verification demonstrating failure at a load exceeding 3,000 pounds.

No fewer than three (3) reinforcing ribs shall be stamped into the bottom of the insert for added strength and rigidity.

The insert shall be designed so the manhole cover does not contact the relief plug during normal installation or removal.

2.3 NITRILE GAS RELIEF PLUG

The insert shall include a Rainstopper Nitrile Gas Relief Plug designed to release at 0.5 to 1.5 PSI with a water leak-down rate not exceeding 5 gallons per 24 hours.

The relief plug shall be factory-installed in a threaded opening and manufactured from nitrile material with no metallic components subject to corrosion from hydrogen sulfide, dilute sulfuric acid, sewer gases, or similar wastewater conditions.

2.4 GASKET

The gasket shall be closed-cell neoprene with pressure-sensitive adhesive, factory-installed, and compatible with the insert material to provide a durable bond in wet or dry conditions.

2.5 HANDLE

The insert shall include a nylon web handle attached with a #6 high-grade stainless-steel rivet and washers.

The handle shall not interfere with manhole cover installation or removal and shall withstand a pull force of not less than 500 pounds before failure or separation from the insert..

③ INSTALLATION

The manhole frame rim shall be cleaned of all dirt, debris, rust scale, and other foreign materials prior to installation. The Rainstopper insert shall be fully seated around the manhole frame rim to minimize water seepage between the insert and frame.

A generous coating of grease on the gasket is recommended to aid seating, improve sealing, and help prevent corrosion.

④ MANUFACTURER

The manhole insert shall be manufactured by:

Southwestern Packing and Seals Company, Inc. DBA Rainstoppers

6905 Westport Avenue

Shreveport, LA 71129

Phone: (318) 687-4330

Email: info@rainstoppercompany.com

Website: www.rainstoppercompany.com

⑤ AMERICAN MADE / BABA COMPLIANCE

Rainstopper inserts are manufactured in the United States and comply with Build America, Buy America (BABA) requirements applicable to federally funded infrastructure projects.

⑥ LIMITED WARRANTY

Rainstopper provides a limited fifteen-year replacement warranty.

If an insert is found to be defective in materials or workmanship within fifteen (15) years of purchase, Rainstopper will replace the insert at no charge, provided the product has not been damaged through mishandling, accident, improper installation, or abnormal use.

This warranty excludes replacement of handle and relief plug components.